


<h2 style="margin: 0;">VERIFICATION REPORT</h2> <h3 style="margin: 0;">The requirement on Grid Connection of Provincial Electricity Authority B.E. 2559 (2016)</h3>	
Report No.	162/65-002
EUT No.	SC-64-0182
Laboratory Name	Electrical and Electronic Products Testing Center
Address	141 Thailand Science Park, Innovation Cluster 2 Tower D, Phahonyothin Rd., Khlong Nueng, Khlong Luang, Pathum Thani 12120, Thailand
Applicant's Name	Jiangsu Goodwe Power Supply Technology Co., Ltd.
Address	No.90 ZiJin Rd., New District, Suzhou, 215011, China
Test specification	
Standard	IEC 61727:2004, IEC 62116:2008, Deviations for Thailand according the grid-connected inverter regulations of the Provincial Electricity Authority (PEA:2016)
Non-standard test method	-
Test item description	
Trademark	Grid-tied photovoltaic inverter 
Model and/or type reference	GW30K-MT
Date of receipt	11 October 2021
Date of report issue	12 October 2021

Prepare by

T. Eakkachai

Eakkachai Taesanoo
Engineer

Approved by

N. Ruengrit

Ruengrit Niniae
Operation Manager

This test report is test results from the EUT only, not the product's quality certificate. It shall not be reproduced except in full without the written approval by PTEC.

Detail of reference test report	
Test Report No.....:	PVTH2103WDG0205-5
Total number of pages.....:	62
Testing Laboratory.....:	Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch No. 96, Guantai Road (Houjie Section), Houjie Town, Dongguan City, Guangdong Province, 523942, People's Republic of China
Testing location.....:	Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch No. 96, Guantai Road (Houjie Section), Houjie Town, Dongguan City, Guangdong Province, 523942, People's Republic of China
Test specification.....:	IEC 61727:2004, IEC 62116:2008, Deviations for Thailand according the grid-connected inverter regulations of the Provincial Electricity Authority (PEA:2016)
Tested by.....:	Colin Chen
Reviewed by.....:	-
Approved by.....:	Ken Chan
Date of report issue.....:	2021-09-26

Test item description	Grid-Tied PV Inverter
Trademark	GOODWE
Model and/or type reference	GW30K-MT
Rating	
Input DC MPP voltage range [V]:	200-950
Input DC voltage Max [V].....:	1100
Input DC current [A].....:	30A / 30A / 30A
Output AC voltage [V]	3/N/PE~400 or 3/PE~400, 50Hz
Output AC current [A].....:	48
Output power [kW].....:	30
Firmware Version	V1.11.11.12

This test report is test results from the EUT only, not the product's quality certificate. It shall not be reproduced except in full without the written approval by PTEC.

Summary of verification report

Test result of report No. **PVTH2103WDG0205-5** was result of Photovoltaic Grid-Tied Inverter model **GW30K-MT**. It was verified by Electrical and Electronic Products Testing Center (PTEC) and **complied** according to Requirements on Grid Connection of Provincial Electricity Authority BE 2559 (2016) as following.


No.	Item	Reference Report No.	Standard Reference	Verdict
1	Active power control	PVTH2103WDG0205-5	PEA	Pass
2	Reactive power control	-	-	-
2.1	A Fixed Displacement Factor $\cos \theta$	PVTH2103WDG0205-5	PEA	Pass
2.2	A variable reactive power depending on the voltage Q(U)	-	-	-
3	Under/over frequency protection	PVTH2103WDG0205-5	IEC 61727	Pass
4	Voltage fluctuation	PVTH2103WDG0205-5	IEC 61000-3-11	Pass
5	Harmonics	PVTH2103WDG0205-5	IEEE 1547.1	Pass
6	DC injection	PVTH2103WDG0205-5	IEC 61727	Pass
7	Low voltage fault ride through	-	-	-
8	Under/over voltage protection	PVTH2103WDG0205-5	IEC 61727	Pass
9	Anti-islanding	PVTH2103WDG0205-5	IEC 62116	Pass
10	Response to utility recovery	PVTH2103WDG0205-5	IEC 61727	Pass

This report consists of the following document:


1. Verification Result (11 Page)
2. Attach Document Reference Report No. PVTH2103WDG0205-5 (62 Page)

Standard Reference.

- **IEEE 1547.1 2005** Interconnecting Distributed Resources with Electric Power Systems
- **IEC 62116:2008**: Utility-interconnected photovoltaic inverters - Test procedure of islanding prevention measures
- **IEC 61727** Photovoltaic (PV) systems - Characteristics of the utility interface
- **IEC 61000-3-11**: Electromagnetic compatibility (EMC) - Part 3-11: Limits - Limitation of voltage fluctuations and flicker in low-voltage power supply systems for equipment with rated current > 75 A
- **PEA**: Thailand according to the grid-connected inverter regulations of the Provincial Electricity Authority (PEA):2016

VERIFICATION REPORT			
Clause	PEA Requirement	Result – Remark	Verdict
8.1.2	<p>Active Power Control</p> <p>The power generating system of VSPP must be capable of reducing electric power from 100% to zero by decreasing 10 % electric power per one minute .In this regard, if there is any abnormality occurred in the grid system or any incident considered by PEA as an impact affecting safety and stability of the grid system, PEA would inform and/or give an order to the VSPP to reduce electric power as appropriate.</p>	<p>Active Power Control</p> <p>1) Requirement The requirements on Grid Connection of Provincial Electricity Authority</p> <p>2) Test result See Test report no : PVTH2103WDG0205-5, Page 45</p> <p>3) Verification test result</p>  <p>The PV inverter is capable of reducing electric power from 100 % to zero by decreasing 10 % electric power per one minute.</p>	Pass
8.1.3	<p>Reactive Power Control</p> <p>The power generating system of VSPP must be able to control power factor)PF (or reactive power to maintain voltage level at PCC aligned with PEA's standards .The power generating system of service applicants must have capacity as stated in Table 1.</p>	<p>Reactive Power Control</p> <p>1) Requirement The requirements on Grid Connection of Provincial Electricity Authority</p> <p>2) Test result See Test report no : PVTH2103WDG0205-5, <ul style="list-style-type: none"> - Page 40 Reactive power capability - Page 41-42 A Fixed Displacement Factor cos θ test result. - No A variable reactive power depending on the voltage Q(U) test result. </p>	Pass

This test report is test results from the EUT only, not the product's quality certificate. It shall not be reproduced except in full without the written approval by PTEC.

VERIFICATION REPORT																	
Clause	PEA Requirement	Result – Remark	Verdict														
		<p>3) Verification test result</p> <p>3.1 Reactive power capability</p> 	Pass														
		<p>3.2 A Fixed Displacement Factor $\cos \theta$ test</p> <table border="1" data-bbox="804 913 1366 1075"> <thead> <tr> <th rowspan="2">PF. Set point</th> <th colspan="2">PF. Measurement*</th> </tr> <tr> <th>Max</th> <th>Min</th> </tr> </thead> <tbody> <tr> <td>1.0</td> <td>0.999</td> <td>0.999</td> </tr> <tr> <td>0.95 lagging</td> <td>0.960</td> <td>0.950</td> </tr> <tr> <td>0.95 Leading</td> <td>0.949</td> <td>0.941</td> </tr> </tbody> </table> <p>*@Pout =10% to 100%</p>	PF. Set point	PF. Measurement*		Max	Min	1.0	0.999	0.999	0.95 lagging	0.960	0.950	0.95 Leading	0.949	0.941	Pass
PF. Set point	PF. Measurement*																
	Max	Min															
1.0	0.999	0.999															
0.95 lagging	0.960	0.950															
0.95 Leading	0.949	0.941															
		<p>3.3 A variable reactive power depending on the voltage Q (U) test</p> <p>-</p>	-														
8.2	<p>Under and Over Frequency Protection</p> <p>The power generating system of VSPP must disconnect itself from the grid system within 0.1 seconds if the frequency at PCC is not in the range of 47 Hz-52 Hz.</p>	<p>Under and Over Frequency Protection</p> <p>1) Reference Standard IEEE 1547,1-2005</p> <p>2) Test result See Test report no: PVTH2103WDG0205-5 Page 30-31</p> <p>3) Verification test result</p> <table border="1" data-bbox="804 1742 1366 1921"> <thead> <tr> <th>Frequency at PCC</th> <th>Measured (Sec)</th> <th>Limit (Sec)</th> <th>Result</th> </tr> </thead> <tbody> <tr> <td>f < 47</td> <td>0.0665</td> <td><0.1</td> <td>Pass</td> </tr> <tr> <td>f > 52</td> <td>0.0660</td> <td><0.1</td> <td>Pass</td> </tr> </tbody> </table>	Frequency at PCC	Measured (Sec)	Limit (Sec)	Result	f < 47	0.0665	<0.1	Pass	f > 52	0.0660	<0.1	Pass	Pass		
Frequency at PCC	Measured (Sec)	Limit (Sec)	Result														
f < 47	0.0665	<0.1	Pass														
f > 52	0.0660	<0.1	Pass														

This test report is test results from the EUT only, not the product's quality certificate. It shall not be reproduced except in full without the written approval by PTEC.

VERIFICATION REPORT															
Clause	PEA Requirement	Result – Remark	Verdict												
8.3	<p>Voltage Fluctuation The power generating system of VSPP must not create voltage fluctuation exceeding the limit based on the PEA's rules concerning the Regulations on Grid Connection B.E.2559.</p> <p>Regulations on Grid Connection B.E.2559. The operation of the inverter should not cause voltage flicker in excess of limits : Short-term Severity Values (Pst) not exceed 1.0 Long-term Severity Values (Plt) not exceed 0.8</p>	<p>Voltage Fluctuation 1) Reference Standard IEC 61000-3-11</p> <p>2) Test result See Test report no : PVTH2103WDG0205-5, Page 14</p> <p>3) Verification test result</p> <table border="1"> <thead> <tr> <th>Test item</th> <th>Limit</th> <th>Result</th> <th>Verdict</th> </tr> </thead> <tbody> <tr> <td>Pst</td> <td>1.0</td> <td>0.296</td> <td>Pass</td> </tr> <tr> <td>Plt</td> <td>0.8</td> <td>0.290</td> <td>Pass</td> </tr> </tbody> </table>	Test item	Limit	Result	Verdict	Pst	1.0	0.296	Pass	Plt	0.8	0.290	Pass	Pass
Test item	Limit	Result	Verdict												
Pst	1.0	0.296	Pass												
Plt	0.8	0.290	Pass												

This test report is test results from the EUT only, not the product's quality certificate. It shall not be reproduced except in full without the written approval by PTEC.

VERIFICATION REPORT																																																																																																																																																																																	
Clause	PEA Requirement	Result – Remark	Verdict																																																																																																																																																																														
8.4	<p>Harmonic</p> <p>The power generating system of VSPP must not inject harmonic current to the grid system exceeding the limit based on the PEA’s rules concerning the Regulations of Grid Connection B.E.2559.</p> <p>Regulations of Grid Connection B.E.2559.</p> <p>The Inverter output should have low current-distortion and low voltage distortion levels to ensure that no adverse effects are caused to other equipment connected to the utility system .Each individual harmonic shall be limited to the listed in Table 5.1 and Table 5-2 of attach 4.</p> <p style="text-align: center;">ตารางที่ 5-1 ขีดจำกัดกระแสฮาร์มอนิกสำหรับผู้ใช้ไฟฟ้าแรงดันที่จุดต่อร่วม *</p> <table border="1"> <thead> <tr> <th rowspan="2">ระดับแรงดันไฟฟ้าที่จุดต่อร่วม (kV)</th> <th colspan="19">อันดับฮาร์มอนิกและขีดจำกัดของกระแส (A rms)</th> </tr> <tr> <th>2</th><th>3</th><th>4</th><th>5</th><th>6</th><th>7</th><th>8</th><th>9</th><th>10</th><th>11</th><th>12</th><th>13</th><th>14</th><th>15</th><th>16</th><th>17</th><th>18</th><th>19</th> </tr> </thead> <tbody> <tr> <td>0.400</td> <td>48</td><td>34</td><td>22</td><td>56</td><td>11</td><td>40</td><td>9</td><td>8</td><td>7</td><td>19</td><td>6</td><td>16</td><td>5</td><td>5</td><td>6</td><td>4</td><td>6</td> </tr> <tr> <td>11 and 12</td> <td>13</td><td>8</td><td>6</td><td>10</td><td>4</td><td>8</td><td>3</td><td>3</td><td>3</td><td>7</td><td>2</td><td>6</td><td>2</td><td>2</td><td>2</td><td>1</td><td>1</td> </tr> <tr> <td>22 , 24 and 33</td> <td>11</td><td>7</td><td>5</td><td>9</td><td>4</td><td>6</td><td>3</td><td>2</td><td>2</td><td>6</td><td>2</td><td>5</td><td>2</td><td>1</td><td>1</td><td>2</td><td>1</td> </tr> <tr> <td>69</td> <td>8.8</td><td>5.9</td><td>4.3</td><td>7.3</td><td>3.3</td><td>4.9</td><td>2.3</td><td>1.6</td><td>1.6</td><td>4.9</td><td>1.6</td><td>4.3</td><td>1.6</td><td>1</td><td>1</td><td>1.6</td><td>1</td> </tr> <tr> <td>115 and above</td> <td>5</td><td>4</td><td>3</td><td>4</td><td>2</td><td>3</td><td>1</td><td>1</td><td>1</td><td>3</td><td>1</td><td>3</td><td>1</td><td>1</td><td>1</td><td>1</td><td>1</td> </tr> </tbody> </table> <p style="text-align: center;">ตารางที่ 5-2 ขีดจำกัดความเพี้ยนฮาร์มอนิกของแรงดันสำหรับผู้ใช้ไฟฟ้าแรงดันที่จุดต่อร่วม (รวมทั้งระดับความเพี้ยนที่มีอยู่เดิม)</p> <table border="1"> <thead> <tr> <th rowspan="2">ระดับแรงดันไฟฟ้าที่จุดต่อร่วม (kV)</th> <th rowspan="2">ค่าความเพี้ยนฮาร์มอนิกรวมของแรงดัน (%)</th> <th colspan="2">ค่าความเพี้ยนฮาร์มอนิกของแรงดันแต่ละอันดับ (%)</th> </tr> <tr> <th>อันดับที่</th> <th>อันดับที่</th> </tr> </thead> <tbody> <tr> <td>0.400</td> <td>5</td> <td>4</td> <td>2</td> </tr> <tr> <td>11 , 12 , 22 and 24</td> <td>4</td> <td>3</td> <td>1.75</td> </tr> <tr> <td>33</td> <td>3</td> <td>2</td> <td>1</td> </tr> <tr> <td>69</td> <td>2.45</td> <td>1.63</td> <td>0.82</td> </tr> <tr> <td>115 and above</td> <td>1.5</td> <td>1</td> <td>0.5</td> </tr> </tbody> </table>	ระดับแรงดันไฟฟ้าที่จุดต่อร่วม (kV)	อันดับฮาร์มอนิกและขีดจำกัดของกระแส (A rms)																			2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	0.400	48	34	22	56	11	40	9	8	7	19	6	16	5	5	6	4	6	11 and 12	13	8	6	10	4	8	3	3	3	7	2	6	2	2	2	1	1	22 , 24 and 33	11	7	5	9	4	6	3	2	2	6	2	5	2	1	1	2	1	69	8.8	5.9	4.3	7.3	3.3	4.9	2.3	1.6	1.6	4.9	1.6	4.3	1.6	1	1	1.6	1	115 and above	5	4	3	4	2	3	1	1	1	3	1	3	1	1	1	1	1	ระดับแรงดันไฟฟ้าที่จุดต่อร่วม (kV)	ค่าความเพี้ยนฮาร์มอนิกรวมของแรงดัน (%)	ค่าความเพี้ยนฮาร์มอนิกของแรงดันแต่ละอันดับ (%)		อันดับที่	อันดับที่	0.400	5	4	2	11 , 12 , 22 and 24	4	3	1.75	33	3	2	1	69	2.45	1.63	0.82	115 and above	1.5	1	0.5	<p>Harmonics</p> <p>1) Reference Standard IEEE 1547.1-2005 Total harmonic current distortion is less than 5 % at rated inverter output Individual harmonics don't exceed the given distortion limit</p> <p>2) Test result See Test report no : PVTH2103WDG0205-5, Page 16 - 20</p> <p>3) Verification test result</p> <table border="1"> <thead> <tr> <th>%Pout</th> <th>THD (<5%)</th> <th>THDi</th> <th>Verdict</th> </tr> </thead> <tbody> <tr> <td>33%</td> <td>0.446</td> <td rowspan="3">THDi in each harmonic does not exceed in table 5-1</td> <td>Pass</td> </tr> <tr> <td>66%</td> <td>0.531</td> <td>Pass</td> </tr> <tr> <td>100%</td> <td>0.582</td> <td>Pass</td> </tr> </tbody> </table> <table border="1"> <thead> <tr> <th>Item</th> <th>Verdict</th> </tr> </thead> <tbody> <tr> <td>THDv in each harmonic does not exceed in table 5-2</td> <td>Pass</td> </tr> <tr> <td>Total harmonic voltage distortion less than 5 %</td> <td>0.067</td> </tr> </tbody> </table>	%Pout	THD (<5%)	THDi	Verdict	33%	0.446	THDi in each harmonic does not exceed in table 5-1	Pass	66%	0.531	Pass	100%	0.582	Pass	Item	Verdict	THDv in each harmonic does not exceed in table 5-2	Pass	Total harmonic voltage distortion less than 5 %	0.067	Pass
ระดับแรงดันไฟฟ้าที่จุดต่อร่วม (kV)	อันดับฮาร์มอนิกและขีดจำกัดของกระแส (A rms)																																																																																																																																																																																
	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19																																																																																																																																																															
0.400	48	34	22	56	11	40	9	8	7	19	6	16	5	5	6	4	6																																																																																																																																																																
11 and 12	13	8	6	10	4	8	3	3	3	7	2	6	2	2	2	1	1																																																																																																																																																																
22 , 24 and 33	11	7	5	9	4	6	3	2	2	6	2	5	2	1	1	2	1																																																																																																																																																																
69	8.8	5.9	4.3	7.3	3.3	4.9	2.3	1.6	1.6	4.9	1.6	4.3	1.6	1	1	1.6	1																																																																																																																																																																
115 and above	5	4	3	4	2	3	1	1	1	3	1	3	1	1	1	1	1																																																																																																																																																																
ระดับแรงดันไฟฟ้าที่จุดต่อร่วม (kV)	ค่าความเพี้ยนฮาร์มอนิกรวมของแรงดัน (%)	ค่าความเพี้ยนฮาร์มอนิกของแรงดันแต่ละอันดับ (%)																																																																																																																																																																															
		อันดับที่	อันดับที่																																																																																																																																																																														
0.400	5	4	2																																																																																																																																																																														
11 , 12 , 22 and 24	4	3	1.75																																																																																																																																																																														
33	3	2	1																																																																																																																																																																														
69	2.45	1.63	0.82																																																																																																																																																																														
115 and above	1.5	1	0.5																																																																																																																																																																														
%Pout	THD (<5%)	THDi	Verdict																																																																																																																																																																														
33%	0.446	THDi in each harmonic does not exceed in table 5-1	Pass																																																																																																																																																																														
66%	0.531		Pass																																																																																																																																																																														
100%	0.582		Pass																																																																																																																																																																														
Item	Verdict																																																																																																																																																																																
THDv in each harmonic does not exceed in table 5-2	Pass																																																																																																																																																																																
Total harmonic voltage distortion less than 5 %	0.067																																																																																																																																																																																

This test report is test results from the EUT only, not the product's quality certificate. It shall not be reproduced except in full without the written approval by PTEC.

VERIFICATION REPORT																			
Clause	PEA Requirement	Result – Remark	Verdict																
8.5	<p>DC Injection The power generating system of VSPP must not supply direct current to the grid system exceeding the limit based on the PEA’s regulations concerning the Regulations on Grid Connection B.E.2559.</p> <p>Regulations on Grid Connection B.E.2559. The inverter shall not inject DC current greater than 0.5 % of the rated inverter output current, into the utility AC interface under any operating condition.</p>	<p>DC Injection 1) Reference Standard IEC 61727</p> <p>2) Test result See Test report no: PVTH2103WDG0205-5, Page 15</p> <p>3) Verification test result</p> <table border="1"> <thead> <tr> <th>Output Power</th> <th>Limit</th> <th>Max.DC</th> <th>Verdict</th> </tr> </thead> <tbody> <tr> <td>33%</td> <td>0.5%</td> <td>0.127%</td> <td>Pass</td> </tr> <tr> <td>66%</td> <td>0.5%</td> <td>0.446%</td> <td>Pass</td> </tr> <tr> <td>100%</td> <td>0.5%</td> <td>0.483%</td> <td>Pass</td> </tr> </tbody> </table>	Output Power	Limit	Max.DC	Verdict	33%	0.5%	0.127%	Pass	66%	0.5%	0.446%	Pass	100%	0.5%	0.483%	Pass	Pass
Output Power	Limit	Max.DC	Verdict																
33%	0.5%	0.127%	Pass																
66%	0.5%	0.446%	Pass																
100%	0.5%	0.483%	Pass																

This test report is test results from the EUT only, not the product's quality certificate. It shall not be reproduced except in full without the written approval by PTEC.

VERIFICATION REPORT																																																																																																	
Clause	PEA Requirement	Result – Remark	Verdict																																																																																														
12.1	<p>Low Voltage Fault Ride Through The power system of VSPP must not disconnect itself from the grid system within the required period during temporary low voltage of the grid system .The voltage at PCC is determined as shown in Table Fault Ride Through</p> <p>Duration of Low Voltage Fault Ride Through</p> <table border="1"> <thead> <tr> <th>Voltage at PCC</th> <th>Duration Time (Second)</th> </tr> </thead> <tbody> <tr> <td>1) Low voltage 2) Moderate voltage or high voltage (electrical installation not exceeding 500 kilowatt).</td> <td>Not required.</td> </tr> <tr> <td>3) Moderate voltage or high voltage (electrical installation exceeding 500 kilowatt).</td> <td>As shown in Picture 1.</td> </tr> </tbody> </table> <p>Picture 1. Low Voltage Fault Ride Through</p>	Voltage at PCC	Duration Time (Second)	1) Low voltage 2) Moderate voltage or high voltage (electrical installation not exceeding 500 kilowatt).	Not required.	3) Moderate voltage or high voltage (electrical installation exceeding 500 kilowatt).	As shown in Picture 1.	<p>Low Voltage Fault Ride Through</p> <p>1) Requirement The requirements on Grid Connection of Provincial Electricity Authority</p> <p>2) Test result -</p> <p>3) Verification test result</p> <p>3.1) Output Power >0.9Pn</p> <table border="1"> <thead> <tr> <th>Test</th> <th>V (V/Vn)</th> <th>Duration (mS)</th> <th>Limit (mS)</th> <th>verdict</th> </tr> </thead> <tbody> <tr> <td rowspan="3">Three-phase faults</td> <td>0.7-0.8 Vn</td> <td></td> <td>>993.75</td> <td></td> </tr> <tr> <td>0.3-0.5 Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td>0-0.049Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td rowspan="3">Phase to Phase faults</td> <td>0.7-0.8 Vn</td> <td></td> <td>>993.75</td> <td></td> </tr> <tr> <td>0.3-0.5 Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td>0-0.049Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td rowspan="3">Phase to ground faults</td> <td>0.7-0.8 Vn</td> <td></td> <td>>993.75</td> <td></td> </tr> <tr> <td>0.3-0.5 Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td>0-0.049Vn</td> <td></td> <td>>150</td> <td></td> </tr> </tbody> </table> <p>3.2) Output Power 0.3Pn</p> <table border="1"> <thead> <tr> <th>Test</th> <th>V (V/Vn)</th> <th>Duration (mS)</th> <th>Limit (mS)</th> <th>verdict</th> </tr> </thead> <tbody> <tr> <td rowspan="3">Three-phase faults</td> <td>0.7-0.8 Vn</td> <td></td> <td>>993.75</td> <td></td> </tr> <tr> <td>0.3-0.5 Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td>0-0.049Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td rowspan="3">Phase to Phase faults</td> <td>0.7-0.8 Vn</td> <td></td> <td>>993.75</td> <td></td> </tr> <tr> <td>0.3-0.5 Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td>0-0.049Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td rowspan="3">Phase to ground faults</td> <td>0.7-0.8 Vn</td> <td></td> <td>>993.75</td> <td></td> </tr> <tr> <td>0.3-0.5 Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td>0-0.049Vn</td> <td></td> <td>>150</td> <td></td> </tr> </tbody> </table>	Test	V (V/Vn)	Duration (mS)	Limit (mS)	verdict	Three-phase faults	0.7-0.8 Vn		>993.75		0.3-0.5 Vn		>150		0-0.049Vn		>150		Phase to Phase faults	0.7-0.8 Vn		>993.75		0.3-0.5 Vn		>150		0-0.049Vn		>150		Phase to ground faults	0.7-0.8 Vn		>993.75		0.3-0.5 Vn		>150		0-0.049Vn		>150		Test	V (V/Vn)	Duration (mS)	Limit (mS)	verdict	Three-phase faults	0.7-0.8 Vn		>993.75		0.3-0.5 Vn		>150		0-0.049Vn		>150		Phase to Phase faults	0.7-0.8 Vn		>993.75		0.3-0.5 Vn		>150		0-0.049Vn		>150		Phase to ground faults	0.7-0.8 Vn		>993.75		0.3-0.5 Vn		>150		0-0.049Vn		>150		-
Voltage at PCC	Duration Time (Second)																																																																																																
1) Low voltage 2) Moderate voltage or high voltage (electrical installation not exceeding 500 kilowatt).	Not required.																																																																																																
3) Moderate voltage or high voltage (electrical installation exceeding 500 kilowatt).	As shown in Picture 1.																																																																																																
Test	V (V/Vn)	Duration (mS)	Limit (mS)	verdict																																																																																													
Three-phase faults	0.7-0.8 Vn		>993.75																																																																																														
	0.3-0.5 Vn		>150																																																																																														
	0-0.049Vn		>150																																																																																														
Phase to Phase faults	0.7-0.8 Vn		>993.75																																																																																														
	0.3-0.5 Vn		>150																																																																																														
	0-0.049Vn		>150																																																																																														
Phase to ground faults	0.7-0.8 Vn		>993.75																																																																																														
	0.3-0.5 Vn		>150																																																																																														
	0-0.049Vn		>150																																																																																														
Test	V (V/Vn)	Duration (mS)	Limit (mS)	verdict																																																																																													
Three-phase faults	0.7-0.8 Vn		>993.75																																																																																														
	0.3-0.5 Vn		>150																																																																																														
	0-0.049Vn		>150																																																																																														
Phase to Phase faults	0.7-0.8 Vn		>993.75																																																																																														
	0.3-0.5 Vn		>150																																																																																														
	0-0.049Vn		>150																																																																																														
Phase to ground faults	0.7-0.8 Vn		>993.75																																																																																														
	0.3-0.5 Vn		>150																																																																																														
	0-0.049Vn		>150																																																																																														

This test report is test results from the EUT only, not the product's quality certificate. It shall not be reproduced except in full without the written approval by PTEC.

VERIFICATION REPORT																																																	
Clause	PEA Requirement	Result – Remark			Verdict																																												
		3.3) Output Power 0.1Pn <table border="1"> <thead> <tr> <th>Test</th> <th>V (V/Vn)</th> <th>Duration (mS)</th> <th>Limit (mS)</th> <th>verdict</th> </tr> </thead> <tbody> <tr> <td rowspan="3">Three-phase faults</td> <td>0.7-0.8 Vn</td> <td></td> <td>>993.75</td> <td></td> </tr> <tr> <td>0.3-0.5 Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td>0-0.049Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td rowspan="3">Phase to Phase faults</td> <td>0.7-0.8 Vn</td> <td></td> <td>>993.75</td> <td></td> </tr> <tr> <td>0.3-0.5 Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td>0-0.049Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td rowspan="3">Phase to ground faults</td> <td>0.7-0.8 Vn</td> <td></td> <td>>993.75</td> <td></td> </tr> <tr> <td>0.3-0.5 Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td>0-0.049Vn</td> <td></td> <td>>150</td> <td></td> </tr> </tbody> </table>			Test	V (V/Vn)	Duration (mS)	Limit (mS)	verdict	Three-phase faults	0.7-0.8 Vn		>993.75		0.3-0.5 Vn		>150		0-0.049Vn		>150		Phase to Phase faults	0.7-0.8 Vn		>993.75		0.3-0.5 Vn		>150		0-0.049Vn		>150		Phase to ground faults	0.7-0.8 Vn		>993.75		0.3-0.5 Vn		>150		0-0.049Vn		>150		-
Test	V (V/Vn)	Duration (mS)	Limit (mS)	verdict																																													
Three-phase faults	0.7-0.8 Vn		>993.75																																														
	0.3-0.5 Vn		>150																																														
	0-0.049Vn		>150																																														
Phase to Phase faults	0.7-0.8 Vn		>993.75																																														
	0.3-0.5 Vn		>150																																														
	0-0.049Vn		>150																																														
Phase to ground faults	0.7-0.8 Vn		>993.75																																														
	0.3-0.5 Vn		>150																																														
	0-0.049Vn		>150																																														
12.2	<p>Under and Over Voltage Protection The power system of VSPP must disconnect itself from the grid system if voltage level of line to neutral in the utility system is out of ranges as stated in Table 3.</p> <p>Table 3. The Disconnect Duration of Falling Voltage Out of Rated Voltage Ranges</p> <table border="1"> <thead> <tr> <th>Voltage at PCC</th> <th>Disconnect Duration (Second)</th> </tr> </thead> <tbody> <tr> <td>V < 50%</td> <td>0.3</td> </tr> <tr> <td>50% ≤ V < 90%</td> <td>2.0</td> </tr> <tr> <td>90% ≤ V ≤ 110%</td> <td>continual voltage</td> </tr> <tr> <td>110% < V < 120%</td> <td>1.0</td> </tr> <tr> <td>V ≥ 120%</td> <td>0.16</td> </tr> </tbody> </table>	Voltage at PCC	Disconnect Duration (Second)	V < 50%	0.3	50% ≤ V < 90%	2.0	90% ≤ V ≤ 110%	continual voltage	110% < V < 120%	1.0	V ≥ 120%	0.16	<p>Under and Over Voltage Protection 1) Reference Standard IEC 61727</p> <p>2) Test result See Test report no: PVTH2103WDG0205-5 Page 22-27</p> <p>3) Verification test result</p> <table border="1"> <thead> <tr> <th>Voltage at PCC</th> <th>Max Meas. (Sec)</th> <th>Limit (Sec)</th> <th>Result</th> </tr> </thead> <tbody> <tr> <td>V < 50%</td> <td>0.284</td> <td><0.3</td> <td>Pass</td> </tr> <tr> <td>50% ≤ V < 90%</td> <td>1.028</td> <td><2.0</td> <td>Pass</td> </tr> <tr> <td>90% ≤ V ≤ 110%</td> <td>No trip</td> <td>Cont.</td> <td>Pass</td> </tr> <tr> <td>110% < V < 120%</td> <td>0.922</td> <td><1.0</td> <td>Pass</td> </tr> <tr> <td>V ≥ 120%</td> <td>0.144</td> <td><0.16</td> <td>Pass</td> </tr> </tbody> </table>			Voltage at PCC	Max Meas. (Sec)	Limit (Sec)	Result	V < 50%	0.284	<0.3	Pass	50% ≤ V < 90%	1.028	<2.0	Pass	90% ≤ V ≤ 110%	No trip	Cont.	Pass	110% < V < 120%	0.922	<1.0	Pass	V ≥ 120%	0.144	<0.16	Pass	Pass								
Voltage at PCC	Disconnect Duration (Second)																																																
V < 50%	0.3																																																
50% ≤ V < 90%	2.0																																																
90% ≤ V ≤ 110%	continual voltage																																																
110% < V < 120%	1.0																																																
V ≥ 120%	0.16																																																
Voltage at PCC	Max Meas. (Sec)	Limit (Sec)	Result																																														
V < 50%	0.284	<0.3	Pass																																														
50% ≤ V < 90%	1.028	<2.0	Pass																																														
90% ≤ V ≤ 110%	No trip	Cont.	Pass																																														
110% < V < 120%	0.922	<1.0	Pass																																														
V ≥ 120%	0.144	<0.16	Pass																																														

This test report is test results from the EUT only, not the product's quality certificate. It shall not be reproduced except in full without the written approval by PTEC.

VERIFICATION REPORT																			
Clause	PEA Requirement	Result – Remark	Verdict																
12.3	<p>Anti-Islanding In order to prevent anti-islanding while there is no electricity in grid system to be supplied to the power system of VSPP, the power generating system of VSPP must disconnect itself from the utility system within 1 seconds.</p>	<p>Anti-Islanding 1) Reference Standard IEC 62116 2) Test result See Test report no: PVTH2103WDG0205-5 Page 33-39 3) Verification test result</p> <table border="1"> <thead> <tr> <th>% Off P_{ou}_{rating}</th> <th>Maximum Runtime (Sec)</th> <th>Limit (Sec)</th> <th>Result</th> </tr> </thead> <tbody> <tr> <td>100</td> <td>0.117</td> <td>< 1.0</td> <td>Pass</td> </tr> <tr> <td>66</td> <td>0.128</td> <td>< 1.0</td> <td>Pass</td> </tr> <tr> <td>33</td> <td>0.149</td> <td>< 1.0</td> <td>Pass</td> </tr> </tbody> </table>	% Off P _{ou} _{rating}	Maximum Runtime (Sec)	Limit (Sec)	Result	100	0.117	< 1.0	Pass	66	0.128	< 1.0	Pass	33	0.149	< 1.0	Pass	Pass
% Off P _{ou} _{rating}	Maximum Runtime (Sec)	Limit (Sec)	Result																
100	0.117	< 1.0	Pass																
66	0.128	< 1.0	Pass																
33	0.149	< 1.0	Pass																
12.4	<p>Response to Utility Recovery After the power generating system of VSPP disconnect itself from the grid system because of power outage or voltage/frequency is out of the ranges, when the grid system is back to normal, the power system of VSPP must delay the time to reconnect itself to the grid system at a minimum of 20 seconds to 5 minutes.</p>	<p>Response to Utility Recovery 1) Reference Standard IEC 61727 2) Test result See Test report no: PVTH2103WDG0205-5 Page 22-23, 28-30, 32 3) Verification test result</p> <table border="1"> <thead> <tr> <th>Limit Recovery time (Sec)</th> <th>Max. Measurement Recovery time (Sec)</th> <th>Result</th> </tr> </thead> <tbody> <tr> <td>20 - 300</td> <td>41.13</td> <td>Pass</td> </tr> </tbody> </table>	Limit Recovery time (Sec)	Max. Measurement Recovery time (Sec)	Result	20 - 300	41.13	Pass	Pass										
Limit Recovery time (Sec)	Max. Measurement Recovery time (Sec)	Result																	
20 - 300	41.13	Pass																	

----- END OF REPORT -----

This test report is test results from the EUT only, not the product's quality certificate. It shall not be reproduced except in full without the written approval by PTEC.



**BUREAU
VERITAS**

TEST REPORT

IEC 61727 / IEC 62116


Photovoltaic (PV) systems
Characteristics of the utility interface
Test procedure of islanding prevention measures for
utility-interconnected photovoltaic inverters


Report reference number	PVTH2103WDG0205-5
Date of issue	2021-09-26
Testing laboratory name	Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch
Address	No. 96, Guantai Road (Houjie Section), Houjie Town, Dongguan City, Guangdong Province, 523942, People's Republic of China
Accreditation	  Certificate # 2951.01
Applicant's name.....	Jiangsu Goodwe Power Supply Technology Co.,Ltd.
Address	No.90 ZiJin Rd., New District, Suzhou,215011,China
Test specification	
Standard.....	IEC 61727:2004, IEC 62116:2008, Deviations for Thailand according the grid-connected inverter regulations of the Provincial Electricity Authority (PEA:2016)
Test Report Form No.	IEC61727/IEC62116_PEA VER.2
TRF Originator	Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch
Master TRF	Dated 2020-03-20
Test item description	Grid-Tied PV Inverter
Trademark.....	 GOODWE YOUR SOLAR ENGINE
Model / Type	GW30K-MT
<small>This report is governed by, and incorporates by reference, CPS Conditions of Service as posted at the date of issuance of this report at http://www.bureauveritas.com/home/about-us/our-business/cps/about-us/terms-conditions and is intended for your exclusive use. Any copying or replication of this report to or for any other person or entity, or use of our name or trademark, is permitted only with our prior written permission. This report sets forth our findings solely with respect to the test samples identified herein. The results set forth in this report are not indicative or representative of the quality or characteristics of the lot from which a test sample was taken or any similar or identical product unless specifically and expressly noted. Our report includes all of the tests requested by you and the results thereof based upon the information that you provided to us. Measurement uncertainty is only provided upon request for accredited tests. You have 60 days from date of issuance of this report to notify us of any material error or omission caused by our negligence or if you require measurement uncertainty; provided, however, that such notice shall be in writing and shall specifically address the issue you wish to raise. A failure to raise such issue within the prescribed time shall constitute your unqualified acceptance of the completeness of this report, the tests conducted and the correctness of the report contents.</small>	

Ratings	GW30K-MT
MPP DC voltage range [V]	200-950Vd.c.
Input DC voltage [V]	Max 1100Vd.c.
Input DC current [A]	30A / 30A / 30A
Output AC voltage [V]	3/N/PE~400 or 3/PE~400, 50Hz
Output AC current [A]	Max. 48A
Nominal Output power [kW]	30,0
Maximum Output power [kVA]	33,0



Testing Location : **Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch**
Address : No. 96, Guantai Road (Houjie Section), Houjie Town, Dongguan City, Guangdong Province, 523942, People's Republic of China

Tested by
 (name and signature) : Colin Chen 



Approved by
 (name and signature) : Ken Chan 

Manufacturer's name : **Jiangsu Goodwe Power Supply Technology Co.,Ltd.**
Manufacturer address : No.90 ZiJin Rd., New District, Suzhou,215011,China
Factory 1's name : **Jiangsu Goodwe Power Supply Technology Co.,Ltd.**
Factory 1 address : No.90 ZiJin Rd., New District, Suzhou,215011,China
Factory 2's name : **GoodWe(GuangDe) Power Supply Technology Co.,Ltd.**
Factory 2 address : NO.208, TongRui East Road,Guangde, Anhui, ,China

Document History			
Date	Internal reference	Modification / Change / Status	Revision
2021-09-26	Colin Chen	Initial report was written	0
Supplementary information:			

Test items particulars	
Equipment mobility	Permanent connection
Operating condition	Continuous
Class of equipment	Class I
Protection against ingress of water ..	IP66 according to EN 60529
Test case verdicts	
Test case does not apply to the test object	N/A
Test item does meet the requirement	P(ass)
Test item does not meet the requirement	F(ail)
Testing	
Date of receipt of test item	2021-05-04
Date(s) of performance of test	2021-05-04 to 2021-08-24
General remarks:	
<p>The test result presented in this report relate only to the object(s) tested. This report must not be reproduced in part or in full without the written approval of the issuing testing laboratory. "(see Annex #)" refers to additional information appended to the report. "(see appended table)" refers to a table appended to the report. Throughout this report a comma is used as the decimal separator.</p>	
This Test Report consists of the following documents:	
<ol style="list-style-type: none"> 1. Test Results 2. Annex No. 1 –Test equipment list 3. Annex No. 2 –Pictures of the unit 	

Copy of marking plate:

 GOODWE <small>YOUR SOLAR ENGINE</small>
Product: Grid-Tied PV Inverter Model : GW30K-MT
<p>V_{max} PV: 1100V_{d.c.} MPPT voltage range: 200...950V_{d.c.} Max. PV current: 30/30/30A_{d.c.} I_{sc} PV: 37.5/37.5/37.5A_{d.c.}</p>
<p>Rated grid voltage: 3L/N/PE or 3L/PE~ 400V_{a.c.} AC-grid frequency: 50/60Hz Max current: 48A_{a.c.} Rated active power: 30kW Rated apparent power: 30kVA Max apparent power: 33kVA*</p>
<p>Inverter topology: Non-isolated Power factor range: Default >0.99,0.8cap...0.8ind Operating temperature range: -30...60°C Overvoltage-category: DCII;ACIII IP degree: IP65 Protective class: Class I</p>
<p>*:30kVA for Belgium</p>

<p>S/N:</p>
<p>Jiangsu GoodWe Power Supply Technology Co.,Ltd. E-mail: service@goodwe.com 350-00487-01</p>
<p>S/N</p>

General product information:

input of Solar converter can be supplied from PV array.
The Solar converter converts DC voltage into AC voltage.
The DC

The input and output are protected by Varistors to Earth. The unit is providing EMC filtering at the output toward mains. The unit does not provide galvanic separation from input to output (transformerless). The output is switched off redundant by the high power switching bridge and a two relays. This assures that the opening of the output circuit will also operate in case of one error.




Figure 1 – Block diagram

Description of the electrical circuit: (Figure 1):

The internal control is redundant built. It consists of Microcontroller DSP (U401) and MCU (U503).

The DSP (U401) control the relays by switching signals; measures the PV voltage, PV current, Bus voltage, grid voltage, frequency, AC current with injected DC and the array insulation resistance to ground. In addition it tests the current sensors and the RCMU circuit before each start up.

The MCU (U503) is measures the grid voltage, grid frequency, DCI and residual current, also can switch off the relays independently, and communicate with the DSP (U401) each other.

The current is measured by a current sensor. The AC current signal and the injected DC current signal are sent to the DSP (U401). The DSP (U401) tests and calibrates before each start up all current sensors.

The unit provides two relays in series in all output conductors. When single fault applied to one relay, alarm an error code in display panel, another redundant relay provides basic insulation maintained between the PV array and the mains. All the relays are tested before each start up.

The product was tested on:

Hardware: 290-10280
Software: V1.11.11.12




Figure 2 – Photo of software version

**Interface protection settings with deviations according the grid-connected inverter regulations of the Provincial Electricity Authority (PEA:2016)
(Thailand PEA)**

Parameter	Max. clearance time*	Trip setting
Over voltage (level 2)	0,16s	220V +20% (264V)
Over voltage (level 1)	1,0s	220V +10% (242V)
Under voltage (level 1)	2,0s	220V -10% (198V)
Under voltage (level 2)	0,3s	220V -50% (110V)
Over frequency	0,1s	50Hz +4% (52,0Hz)
Under frequency	0,1s	50Hz -6% (47,0Hz)
Reconnection time	20s - 5min	
Permanent DC-injection	0,5% of rated inverter output current	
Loss of main IEC 62116:2008	Inverter shall detect and disconnect within 1s	

* Trip time refers to the time between the abnormal condition occurring and the inverter ceasing to energize the utility line. The PV system control circuits shall actually remain connected to the utility to allow sensing of utility electrical conditions for use by the “reconnect” feature.

IEC61727:2004			
Clause	Requirement – Test	Result – Remark	Verdict
SECTION 4: Utility compatibility			
4	<p>General The quality of power provided by the PV system for the on-site AC loads and for power delivered to the utility is governed by practices and standards on voltage, flicker, frequency, harmonics and power factor. Deviation from these standards represents out-of-bounds conditions and may require the PV system to sense the deviation and properly disconnect from the utility system.</p> <p>All power quality parameters (voltage, flicker, frequency, harmonics, and power factor) must be measured at the utility interface/ point of common coupling unless otherwise specified.</p>	Noticed	P
4.1	<p>Voltage, current and frequency The PV system AC voltage, current and frequency shall be compatible with the utility system.</p>	Derived from tests	P
4.2	<p>Normal voltage operating range Utility-interconnected PV systems do not normally regulate voltage; they inject current into the utility. Therefore, the voltage operating range for PV inverters is selected as a protection function that responds to abnormal utility conditions, not as a voltage regulation function.</p>	Derived from tests	P
4.3	<p>Flicker The operation of the PV system should not cause voltage flicker in excess of limits stated in the relevant sections of IEC 61000-3-3 for systems less than 16 A or IEC 61000-3-5 for systems with current of 16 A and above.</p>	See table 4.3	P
4.4	<p>DC injection The PV system shall not inject DC current greater than 0.5% of the rated inverter output current, into the utility AC interface under any operating condition.</p>	<p>The following deviations were used: Provincial Electricity Authority (PEA:2016)</p> <p>See table 4.4</p>	P
4.5	<p>Normal frequency operating range The PV system shall operate in synchronism with the utility system, and within the frequency trip limits defined in 5.2.2.</p>	<p>The following deviations were used: Provincial Electricity Authority (PEA:2016)</p> <p>See table 5.2.2</p>	P

IEC61727:2004			
Clause	Requirement – Test	Result – Remark	Verdict
SECTION 4: Utility compatibility			
4.6	<p>Harmonics and waveform distortion Low levels of current and voltage harmonics are desirable; the higher harmonic levels increase the potential for adverse effects on connected equipment. Acceptable levels of harmonic voltage and current depend upon distribution system characteristics, type of service, connected loads/apparatus, and established utility practice. The PV system output should have low current-distortion levels to ensure that no adverse effects are caused to other equipment connected to the utility system. Total harmonic current distortion shall be less than 5 % at rated inverter output. Each individual harmonic shall be limited to the percentages listed in Table 1. Even harmonics in these ranges shall be less than 25 % of the lower odd harmonic limits listed. (see Clause 4.6 Table 1 – Current distortion limits)</p>	<p>The following deviations were used: Provincial Electricity Authority (PEA:2016) See tables 4.6 (1) and 4.6 (2)</p>	P
4.7	<p>Power factor The PV system shall have a lagging power factor greater than 0,9 when the output is greater than 50 % of the rated inverter output power.</p>	See table 3.4	P

IEC61727:2004			
Clause	Requirement – Test	Result – Remark	Verdict
SECTION 5: Personnel safety and equipment protection			
5	General This Clause provides information and considerations for the safe and proper operation of the utility-connected PV systems.	Noticed	P
5.1	Loss of utility voltage To prevent islanding, a utility connected PV system shall cease to energize the utility system from a de-energized distribution line irrespective of connected loads or other generators within specified time limits. A utility distribution line can become de-energized for several reasons. For example, a substation breaker opening due to fault conditions or the distribution line switched out during maintenance. If inverters (single or multiple) have DC SELV input and have accumulated power below 1 kW then no mechanical disconnect (relay) is required.	The following deviations were used: Provincial Electricity Authority (PEA:2016)	P
5.2	Over/under voltage and frequency Abnormal conditions can arise on the utility system that requires a response from the connected photovoltaic system. This response is to ensure the safety of utility maintenance personnel and the general public, as well as to avoid damage to connected equipment, including the photovoltaic system. The abnormal utility conditions of concern are voltage and frequency excursions above or below the values stated in this Clause, and the complete disconnection of the utility, presenting the potential for a distributed resource island.	The following deviations were used: Provincial Electricity Authority (PEA:2016) See table 5.2.1 and 5.2.2	P
5.2.1	Over/under voltage When the interface voltage deviates outside the conditions specified in Table 2, the photovoltaic system shall cease to energize the utility distribution system. This applies to any phase of a multiphase system. All discussions regarding system voltage refer to the local nominal voltage. The system shall sense abnormal voltage and respond. The following conditions should be met, with voltages in RMS and measured at the point of utility connection. (see clause 5.2.1 Table 2 – Response to abnormal voltages) The purpose of the allowed time delay is to ride through short-term disturbances to avoid excessive nuisance tripping. The unit does not have to cease to energize if the voltage returns to the normal utility continuous operation condition within the specified trip time.	The following deviations were used: Provincial Electricity Authority (PEA:2016) See table 5.2.1	P

IEC61727:2004			
Clause	Requirement – Test	Result – Remark	Verdict
SECTION 5: Personnel safety and equipment protection			
5.2.2	Over/under frequency When the utility frequency deviates outside the specified conditions the photovoltaic system shall cease to energize the utility line. The unit does not have to cease to energize if the frequency returns to the normal utility continuous operation condition within the specified trip time. When the utility frequency is outside the range of ± 1 Hz, the system shall cease to energize the utility line within 0,2 s. The purpose of the allowed range and time delay is to allow continued operation for short-term disturbances and to avoid excessive nuisance tripping in weak-utility system conditions.	The following deviations were used: Provincial Electricity Authority (PEA:2016) See table 5.2.2	P
5.3	Islanding protection The PV system must cease to energize the utility line within 2 s of loss of utility.	The following deviations were used: Provincial Electricity Authority (PEA:2016) See table 6.1	P
5.4	Response to utility recovery Following an out-of-range utility condition that has caused the photovoltaic system to cease energizing, the photovoltaic system shall not energize the utility line for 20 s to 5 min after the utility service voltage and frequency have recovered to within the specified ranges.	See table 5.2.1 and 5.2.2	P
5.5	Earthing The utility interface equipment shall be earthed/grounded in accordance with IEC 60364-7-712.	Stated in the manual.	P
5.6	Short circuit protection The photovoltaic system shall have short-circuit protection in accordance with IEC 60364-7-712.	Stated in the manual.	P
5.7	Isolation and switching A method of isolation and switching shall be provided in accordance with IEC 60364-7-712.	Stated in the manual.	P

Test overview:		
IEC 61727:2004		
Clause	Type Test	Result
4	Type test:	
4.3	Voltage Fluctuations and Flicker (see Annex 1 EMC Report)	P
4.4	Monitoring of DC-Injection	P
4.5	Normal frequency operating range (see 5.2.2 below)	P
4.6	Harmonics and waveform distortion	P
4.7	Power factor	P
5.2.1	Voltage monitoring	P
5.2.2	Frequency monitoring	P

IEC 62116:2008		
Clause	Type Test	Result
6.1	Islanding protection according table 6 - Load imbalance (real, reactive load) for test condition A (EUT output = 100%)	P
6.1	Load imbalance (reactive load) for test condition B (EUT output = 50 % – 66 %)	P
6.1	Load imbalance (reactive load) for test condition C (EUT output = 25 % – 33 %)	P

Deviations for Thailand according the grid-connected inverter regulations of the Provincial Electricity Authority (PEA:2016)		
Clause	Type Test	Result
3.4	Reactive power control	
3.4.1, 8.1.2	A fixed displacement factor $\cos\phi$	P
3.4.2, 8.1.2	A variable reactive power depending on the voltage Q(U)	N/A
3.5, 12.1	Active power control	P
3.6, 12.2	Low voltage fault ride through capability	N/A

Test Results


4.3 Voltage fluctuation and flicker 3.2, 8.3 Voltage Fluctuation Regulation (PEA 2016)				P
Test conditions:	Maximum permissible voltage fluctuation (expressed as a percentage of nominal voltage at 100 % power) and flicker as per EN 61000-3-11			
	Starting	Stopping	Running	
Limit	3,3%	3,3%	$P_{st}=1,0$	$P_{it}=0,8$
Test value	*	*	*	*
inverter >16A				
Limit	dc% = 3,3	$P_{st}=1,0$	$P_{it}=0,8$	
Test value	*	L1: 0,154	L1: 0,148	
	*	L2: 0,296	L2: 0,290	
	*	L3: 0,137	L3: 0,131	
Note:				
*The stationary deviance of dc% is more relevant than the dynamic deviance of d_{max} at starting and stopping.				
Mains Impedance according EN61000-3-11: $R_{max} = 0,24\Omega$; $jX_{max} = 0,15\Omega @50Hz$ ($ Z_{max} = 0,283 \Omega$) for single phase inverter use also $R_n = 0,1\Omega$; $jX_n = 0,1\Omega$				
Calculation of the maximum permissible grid impedance at the point of common coupling based on dc: $Z_{max} = Z_{ref} * 3,3\% / dc(P_n)$				
The tests should be based on the limits of the EN 61000-3-11 for more than 16A.				

4.4 Monitoring of Permanent DC-Injection
3.3, 8.5 Direct Current Dispatch to the Power Network System (PEA:2016)

P

PEA Limit:	0,5% of I_{nom} : 227mA		
Output power:	33%	66%	100%
Max. test value (mA): L1 phase	57,5	129,3	147,5
Mean test value(mA) : L1 phase	42,0	34,2	37,3
Max. test value (mA): L2 phase	53,9	123,5	133,6
Mean test value (mA): L2 phase	34,0	43,9	49,9
Max. test value (mA): L3 phase	56,0	202,3	219,4
Mean test value (mA): L3 phase	42,5	49,7	59,0

Diagram of permanent DC-injection



Note:

4.6 Harmonic Current Limit Test the grid-connected inverter regulations of the Provincial Electricity Authority (PEA:2016)								P
33% Output Power								
Watts (W)			3299,082	3330,088	3338,846			
VA (VA)			3302,329	3338,564	3342,640			
Vrms (V)			220,295	220,496	220,102			
Arms (A)			15,002	15,002	15,139			
PF			1,00					
Frequency (Hz)			50,00					
THD50 (%)			0,382	0,382	0,446			
Harmonics	Current Magnitude [A]			% of Rated Current			Phase	Harmonic Current Limits [%]
1st	15,002	15,002	15,139	32,972	32,972	33,272	Three Phase	--
2nd	0,058	0,058	0,109	0,127	0,127	0,240	Three Phase	1
3rd	0,037	0,037	0,050	0,082	0,082	0,110	Three Phase	4
4th	0,020	0,020	0,030	0,045	0,045	0,066	Three Phase	1
5th	0,045	0,045	0,083	0,099	0,099	0,181	Three Phase	4
6th	0,033	0,033	0,015	0,071	0,071	0,033	Three Phase	1
7th	0,058	0,058	0,016	0,127	0,127	0,035	Three Phase	4
8th	0,014	0,014	0,026	0,032	0,032	0,057	Three Phase	1
9th	0,055	0,055	0,014	0,122	0,122	0,031	Three Phase	4
10th	0,018	0,018	0,021	0,040	0,040	0,046	Three Phase	1
11th	0,014	0,014	0,048	0,032	0,032	0,105	Three Phase	2
12th	0,019	0,019	0,011	0,041	0,041	0,023	Three Phase	0,5
13th	0,028	0,028	0,016	0,061	0,061	0,036	Three Phase	2
14th	0,019	0,019	0,012	0,041	0,041	0,026	Three Phase	0,5
15th	0,019	0,019	0,013	0,041	0,041	0,029	Three Phase	2
16th	0,018	0,018	0,027	0,039	0,039	0,060	Three Phase	0,5
17th	0,014	0,014	0,034	0,031	0,031	0,075	Three Phase	1,5
18th	0,020	0,020	0,010	0,044	0,044	0,021	Three Phase	0,375
19th	0,016	0,016	0,026	0,036	0,036	0,058	Three Phase	1,5
20th	0,033	0,033	0,016	0,072	0,072	0,036	Three Phase	0,375
21th	0,020	0,020	0,012	0,044	0,044	0,027	Three Phase	1,5
22th	0,025	0,025	0,031	0,056	0,056	0,068	Three Phase	0,375
23th	0,026	0,026	0,031	0,057	0,057	0,068	Three Phase	0,6
24th	0,019	0,019	0,010	0,042	0,042	0,022	Three Phase	0,15
25th	0,021	0,021	0,037	0,045	0,045	0,082	Three Phase	0,6
26th	0,035	0,035	0,023	0,076	0,076	0,050	Three Phase	0,15
27th	0,014	0,014	0,009	0,031	0,031	0,019	Three Phase	0,6
28th	0,032	0,032	0,033	0,071	0,071	0,072	Three Phase	0,15
29th	0,023	0,023	0,020	0,050	0,050	0,045	Three Phase	0,6
30th	0,015	0,015	0,012	0,034	0,034	0,026	Three Phase	0,15
31th	0,019	0,019	0,030	0,041	0,041	0,066	Three Phase	0,6
32th	0,029	0,029	0,025	0,063	0,063	0,056	Three Phase	0,15
33th	0,013	0,013	0,008	0,028	0,028	0,016	Three Phase	0,6
34th	0,026	0,026	0,022	0,057	0,057	0,048	Three Phase	0,15
35th	0,017	0,017	0,014	0,037	0,037	0,030	Three Phase	0,3



36th	0,010	0,010	0,010	0,022	0,022	0,021	Three Phase	0,075
37th	0,011	0,011	0,015	0,023	0,023	0,034	Three Phase	0,3
38th	0,016	0,016	0,022	0,035	0,035	0,047	Three Phase	0,075
39th	0,007	0,007	0,007	0,016	0,016	0,015	Three Phase	0,3
40th	0,020	0,020	0,016	0,043	0,043	0,035	Three Phase	0,075
41th	0,009	0,009	0,010	0,020	0,020	0,023	Three Phase	N/A
42th	0,007	0,007	0,008	0,016	0,016	0,018	Three Phase	N/A
43th	0,017	0,017	0,016	0,038	0,038	0,035	Three Phase	N/A
44th	0,011	0,011	0,017	0,024	0,024	0,038	Three Phase	N/A
45th	0,007	0,007	0,008	0,016	0,016	0,018	Three Phase	N/A
46th	0,014	0,014	0,015	0,032	0,032	0,034	Three Phase	N/A
47th	0,021	0,021	0,020	0,046	0,046	0,045	Three Phase	N/A
48th	0,007	0,007	0,008	0,016	0,016	0,018	Three Phase	N/A
49th	0,020	0,020	0,020	0,045	0,045	0,043	Three Phase	N/A
50th	0,011	0,011	0,012	0,025	0,025	0,027	Three Phase	N/A

66% Output Power								
Watts (W)				6642,913		6679,319		6689,267
VA (VA)				6644,417		6681,851		6690,009
Vrms (V)				220,711		220,686		220,550
Arms (A)				30,105		30,278		30,333
PF				1,00				
Frequency (Hz)				50,00				
THD50 (%)				0,442		0,513		0,531
Harmonics	Current Magnitude [A]			% of Rated Current			Phase	Harmonic Current Limits [%]
1st	30,103	30,276	30,332	66,162	66,540	66,663	Three Phase	--
2nd	0,052	0,111	0,080	0,114	0,243	0,176	Three Phase	1
3rd	0,058	0,088	0,105	0,127	0,194	0,231	Three Phase	4
4th	0,034	0,044	0,062	0,076	0,096	0,137	Three Phase	1
5th	0,048	0,073	0,047	0,105	0,161	0,103	Three Phase	4
6th	0,034	0,032	0,041	0,075	0,070	0,089	Three Phase	1
7th	0,075	0,038	0,066	0,164	0,083	0,145	Three Phase	4
8th	0,023	0,035	0,044	0,051	0,077	0,098	Three Phase	1
9th	0,057	0,025	0,062	0,125	0,054	0,136	Three Phase	4
10th	0,023	0,026	0,029	0,051	0,057	0,063	Three Phase	1
11th	0,030	0,036	0,031	0,066	0,079	0,068	Three Phase	2
12th	0,022	0,026	0,028	0,048	0,058	0,062	Three Phase	0,5
13th	0,029	0,030	0,029	0,065	0,065	0,064	Three Phase	2
14th	0,021	0,026	0,029	0,047	0,058	0,064	Three Phase	0,5
15th	0,029	0,025	0,034	0,063	0,054	0,075	Three Phase	2
16th	0,020	0,024	0,024	0,044	0,054	0,052	Three Phase	0,5
17th	0,036	0,031	0,021	0,079	0,068	0,047	Three Phase	1,5
18th	0,022	0,023	0,025	0,049	0,050	0,056	Three Phase	0,375
19th	0,030	0,026	0,024	0,066	0,057	0,053	Three Phase	1,5
20th	0,022	0,024	0,032	0,049	0,052	0,070	Three Phase	0,375
21th	0,028	0,023	0,034	0,063	0,051	0,076	Three Phase	1,5
22th	0,018	0,027	0,027	0,039	0,058	0,058	Three Phase	0,375

23th	0,025	0,034	0,019	0,055	0,074	0,042	Three Phase	0,6
24th	0,019	0,021	0,022	0,041	0,045	0,049	Three Phase	0,15
25th	0,037	0,025	0,024	0,082	0,054	0,053	Three Phase	0,6
26th	0,024	0,026	0,035	0,054	0,057	0,077	Three Phase	0,15
27th	0,018	0,023	0,026	0,039	0,050	0,058	Three Phase	0,6
28th	0,022	0,032	0,031	0,049	0,071	0,068	Three Phase	0,15
29th	0,031	0,041	0,028	0,067	0,090	0,062	Three Phase	0,6
30th	0,019	0,022	0,023	0,042	0,048	0,052	Three Phase	0,15
31th	0,032	0,025	0,027	0,071	0,055	0,059	Three Phase	0,6
32th	0,030	0,024	0,034	0,066	0,053	0,075	Three Phase	0,15
33th	0,020	0,022	0,023	0,043	0,049	0,051	Three Phase	0,6
34th	0,026	0,034	0,031	0,057	0,076	0,068	Three Phase	0,15
35th	0,025	0,032	0,024	0,056	0,071	0,052	Three Phase	0,3
36th	0,014	0,012	0,011	0,030	0,027	0,024	Three Phase	0,075
37th	0,020	0,016	0,018	0,043	0,036	0,040	Three Phase	0,3
38th	0,017	0,014	0,017	0,037	0,032	0,037	Three Phase	0,075
39th	0,011	0,011	0,012	0,024	0,024	0,026	Three Phase	0,3
40th	0,014	0,017	0,015	0,030	0,037	0,034	Three Phase	N/A
41th	0,011	0,018	0,016	0,025	0,041	0,035	Three Phase	N/A
42th	0,009	0,009	0,009	0,019	0,020	0,020	Three Phase	N/A
43th	0,011	0,009	0,010	0,025	0,021	0,022	Three Phase	N/A
44th	0,014	0,011	0,012	0,030	0,024	0,027	Three Phase	N/A
45th	0,008	0,008	0,008	0,017	0,017	0,018	Three Phase	N/A
46th	0,014	0,016	0,014	0,031	0,036	0,031	Three Phase	N/A
47th	0,007	0,010	0,008	0,016	0,021	0,017	Three Phase	N/A
48th	0,007	0,008	0,007	0,016	0,017	0,016	Three Phase	N/A
49th	0,028	0,026	0,023	0,062	0,056	0,051	Three Phase	N/A
50th	0,013	0,014	0,012	0,028	0,030	0,027	Three Phase	N/A

100% Output Power				
Watts (W)	9954,417		9994,894	10013,001
VA (VA)	9956,053		9997,829	10013,952
Vrms (V)	221,054		220,969	220,838
Arms (A)	45,039		45,245	45,345
PF	1,00			
Frequency (Hz)	50,00			
THD50 (%)	0,514	0,562	0,582	

Harmonics	Current Magnitude [A]			% of Rated Current			Phase	Harmonic Current Limits [%]
	1	2	3	1	2	3		
1st	45,036	45,241	45,341	98,980	99,431	99,651	Three Phase	--
2nd	0,055	0,103	0,083	0,121	0,227	0,182	Three Phase	1
3rd	0,064	0,066	0,083	0,141	0,144	0,182	Three Phase	4
4th	0,058	0,040	0,080	0,127	0,089	0,176	Three Phase	1
5th	0,044	0,109	0,074	0,097	0,240	0,164	Three Phase	4
6th	0,045	0,038	0,052	0,098	0,083	0,115	Three Phase	1
7th	0,080	0,034	0,069	0,177	0,075	0,151	Three Phase	4
8th	0,022	0,031	0,034	0,049	0,068	0,075	Three Phase	1
9th	0,061	0,026	0,072	0,134	0,056	0,158	Three Phase	4



10th	0,026	0,027	0,030	0,056	0,060	0,065	Three Phase	1
11th	0,026	0,045	0,048	0,058	0,100	0,105	Three Phase	2
12th	0,024	0,027	0,031	0,052	0,059	0,068	Three Phase	0,5
13th	0,030	0,032	0,031	0,067	0,071	0,068	Three Phase	2
14th	0,022	0,029	0,029	0,049	0,063	0,063	Three Phase	0,5
15th	0,029	0,027	0,040	0,064	0,059	0,088	Three Phase	2
16th	0,021	0,025	0,026	0,046	0,055	0,056	Three Phase	0,5
17th	0,041	0,031	0,025	0,091	0,068	0,054	Three Phase	1,5
18th	0,023	0,024	0,027	0,050	0,053	0,059	Three Phase	0,375
19th	0,034	0,033	0,024	0,074	0,072	0,053	Three Phase	1,5
20th	0,022	0,026	0,032	0,049	0,058	0,070	Three Phase	0,375
21th	0,029	0,028	0,038	0,063	0,061	0,083	Three Phase	1,5
22th	0,020	0,025	0,027	0,045	0,055	0,060	Three Phase	0,375
23th	0,033	0,030	0,024	0,073	0,065	0,054	Three Phase	0,6
24th	0,019	0,023	0,025	0,042	0,050	0,055	Three Phase	0,15
25th	0,043	0,036	0,022	0,094	0,079	0,048	Three Phase	0,6
26th	0,022	0,027	0,033	0,048	0,060	0,073	Three Phase	0,15
27th	0,020	0,025	0,030	0,045	0,055	0,067	Three Phase	0,6
28th	0,023	0,027	0,030	0,051	0,059	0,066	Three Phase	0,15
29th	0,043	0,048	0,033	0,095	0,105	0,073	Three Phase	0,6
30th	0,022	0,027	0,028	0,048	0,058	0,061	Three Phase	0,15
31th	0,049	0,045	0,034	0,107	0,100	0,074	Three Phase	0,6
32th	0,028	0,028	0,033	0,061	0,062	0,073	Three Phase	0,15
33th	0,027	0,028	0,028	0,059	0,061	0,062	Three Phase	0,6
34th	0,031	0,034	0,035	0,068	0,074	0,078	Three Phase	0,15
35th	0,048	0,051	0,037	0,105	0,112	0,081	Three Phase	0,3
36th	0,017	0,016	0,013	0,038	0,036	0,029	Three Phase	0,075
37th	0,029	0,027	0,023	0,063	0,060	0,051	Three Phase	0,3
38th	0,017	0,017	0,019	0,037	0,036	0,041	Three Phase	0,075
39th	0,014	0,015	0,015	0,031	0,032	0,033	Three Phase	0,3
40th	0,015	0,017	0,018	0,033	0,036	0,039	Three Phase	0,075
41th	0,019	0,028	0,024	0,043	0,062	0,052	Three Phase	N/A
42th	0,010	0,012	0,012	0,023	0,027	0,027	Three Phase	N/A
43th	0,031	0,029	0,027	0,068	0,063	0,060	Three Phase	N/A
44th	0,013	0,012	0,013	0,029	0,027	0,030	Three Phase	N/A
45th	0,009	0,011	0,010	0,020	0,023	0,022	Three Phase	N/A
46th	0,012	0,014	0,014	0,027	0,032	0,031	Three Phase	N/A
47th	0,021	0,029	0,022	0,046	0,063	0,049	Three Phase	N/A
48th	0,009	0,011	0,010	0,020	0,023	0,022	Three Phase	N/A
49th	0,034	0,031	0,033	0,075	0,069	0,072	Three Phase	N/A
50th	0,016	0,012	0,013	0,036	0,026	0,029	Three Phase	N/A

Note: The harmonics are tested and evaluated according the IEEE1547.1-2005 clause 5.11.1 according the grid-connected inverter regulations of the Provincial Electricity Authority (PEA:2016).

4.6 Harmonic Voltage Limit Test the grid-connected inverter regulations of the Provincial Electricity Authority (PEA:2016)								P
Vrms (V)				221,1/221,0/220,8				
Frequency (Hz)				50,00				
THD40 (%)				0,061/0,067/0,063				
Harmonics	Voltage Magnitude [V]			% of Rated Voltage			Phase	Limits [%]
2nd	0,010	0.014	0.011	0.004	0.006	0.005	Three Phase	0,2
3rd	0,020	0.039	0.014	0.009	0.017	0.006	Three Phase	4
4th	0,009	0.028	0.013	0.004	0.012	0.005	Three Phase	0,2
5th	0,104	0.109	0.116	0.045	0.048	0.050	Three Phase	4
6th	0,009	0.011	0.010	0.004	0.005	0.004	Three Phase	0,2
7th	0,038	0.033	0.029	0.016	0.014	0.013	Three Phase	4
8th	0,014	0.017	0.012	0.006	0.008	0.005	Three Phase	0,2
9th	0,033	0.032	0.033	0.014	0.014	0.014	Three Phase	2
10th	0,017	0.018	0.012	0.007	0.008	0.005	Three Phase	0,2
11th	0,019	0.025	0.027	0.008	0.011	0.012	Three Phase	0,1
12th	0,012	0.011	0.009	0.005	0.005	0.004	Three Phase	0,1
13th	0,016	0.014	0.009	0.007	0.006	0.004	Three Phase	0,1
14th	0,010	0.013	0.009	0.004	0.006	0.004	Three Phase	0,1
15th	0,010	0.014	0.008	0.004	0.006	0.004	Three Phase	0,1
16th	0,011	0.014	0.011	0.005	0.006	0.005	Three Phase	0,1
17th	0,015	0.016	0.013	0.006	0.007	0.006	Three Phase	0,1
18th	0,010	0.010	0.010	0.004	0.004	0.004	Three Phase	0,1
19th	0,013	0.011	0.009	0.005	0.005	0.004	Three Phase	0,1
20th	0,010	0.012	0.009	0.004	0.005	0.004	Three Phase	0,1
21th	0,012	0.015	0.009	0.005	0.007	0.004	Three Phase	0,1
22th	0,009	0.012	0.010	0.004	0.005	0.004	Three Phase	0,1
23th	0,012	0.014	0.009	0.005	0.006	0.004	Three Phase	0,1
24th	0,009	0.010	0.010	0.004	0.004	0.004	Three Phase	0,1
25th	0,012	0.011	0.009	0.005	0.005	0.004	Three Phase	0,1
26th	0,009	0.010	0.009	0.004	0.004	0.004	Three Phase	0,1
27th	0,010	0.014	0.009	0.004	0.006	0.004	Three Phase	0,1
28th	0,010	0.010	0.011	0.004	0.004	0.005	Three Phase	0,1
29th	0,011	0.013	0.010	0.005	0.006	0.004	Three Phase	0,1
30th	0,009	0.010	0.010	0.004	0.004	0.004	Three Phase	0,1
31th	0,011	0.011	0.010	0.005	0.005	0.004	Three Phase	0,1
32th	0,010	0.010	0.010	0.004	0.004	0.004	Three Phase	0,1
33th	0,010	0.012	0.010	0.004	0.005	0.004	Three Phase	0,1
34th	0,011	0.011	0.012	0.005	0.005	0.005	Three Phase	0,1
35th	0,013	0.014	0.011	0.005	0.006	0.005	Three Phase	0,1
36th	0,011	0.011	0.010	0.005	0.005	0.004	Three Phase	0,1
37th	0,012	0.012	0.011	0.005	0.005	0.005	Three Phase	0,1
38th	0,010	0.011	0.010	0.004	0.005	0.004	Three Phase	0,1
39th	0,011	0.012	0.009	0.005	0.005	0.004	Three Phase	0,1
40th	0,011	0.011	0.011	0.005	0.005	0.005	Three Phase	0,1

Note: The harmonics are tested and evaluated according the IEEE1547.1-2005 clause 5.11.1 according the grid-connected inverter regulations of the Provincial Electricity Authority (PEA:2016).

4.7 Power factor(PEA) 3.1, 8.4 Harmonic Regulation (PEA: 2016)					P
Test conditions:					
Output power [kW]	~10%	~25%	~50%	~75%	~100%
Test AC voltage [V]					
--	--	--	--	--	--
<p>Note:</p> <p>The PV system shall have a lagging power factor greater than 0,95 when the output is greater than 50% of the rated inverter output power.</p> <p>The letter “i” is short for “inductive” and indicates inductive power factor. In case of capacitive power factor the letter “c” is used instead.</p> <p>Test result refer to table 3.4.1, 8.1.2 1.</p>					

5.2.1 Voltage monitoring 3.7, 12.3 Under and Over Voltage Protection (PEA:2016) 3.10, 12.5 Response to utility recovery (PEA:2016)										P
First Level (Phase to Neutral)										
Test conditions:	Output power:20 KW Frequency: 50Hz									
	Under Voltage					Over Voltage				
	Voltage [V]					Voltage [V]				
Set value	198V					242V				
Measured trip value		All	L1	L2	L3		All	L1	L2	L3
		197,1	197,0	196,8	197,5		241,7	241,7	241,6	241,9
		197,1	197,0	196,8	197,5		241,8	241,7	241,6	242,0
		197,1	197,0	196,8	197,5		241,8	241,7	241,6	242,0
Parameter		Time [s]					Time [s]			
Limit		<= 2,0s					<= 1,0s			
Disconnection time	220V to 203V (4s min) to 193V	All	L1	L2	L3	220V to 237V (2s min) to 247V	All	L1	L2	L3
		1,011	1,013	1,021	1,025		0,915	0,916	0,922	0,912
		1,018	1,009	1,013	1,011		0,902	0,905	0,907	0,911
		1,012	1,028	1,005	1,027		0,911	0,915	0,919	0,914
Reconnection time	20s - 5min	41,13 s				20s - 5min	41,13 s			

Second Level (Phase to Neutral)										
Test conditions:	Output power: 20KW Frequency: 50Hz									
	Under Voltage					Over Voltage				
Parameter		Voltage [V]					Voltage [V]			
Set value		110V					264V			
Measured trip value		All	L1	L2	L3		All	L1	L2	L3
		109,5	109,2	109,4	109,8		263,8	263,7	263,4	264,2
		109,5	109,3	109,4	109,8		263,8	263,8	263,4	264,2
		109,5	109,3	109,4	109,8		263,8	263,8	263,4	264,2
Parameter		Time [ms]					Time [ms]			
Limit		<= 300ms					<= 160ms			
Disconnection time	220V to 203V (0,6s min) to 105V	All	L1	L2	L3	220V to 237V (0,32s min) to 269V	All	L1	L2	L3
		257,0	268,0	262,0	255,0		120,8	142,5	125,5	133,8
		251,0	262,0	260,0	256,0		133,3	128,0	144,5	125,8
		250,0	256,0	284,0	258,0		134,0	133,0	132,8	140,8
Reconnection time	20s - 5min	41,1s			20s - 5min	41,1s				
Note: The tests are according PEA:2016, The voltage settings of the EUT are set for the tests as stated to 198V, 110V for undervoltage and 242V, 264V for overvoltage, Response to utility recovery is according to the appropriate IEEE or IEC standard test methods,										

Under Voltage First Level single phase




Over voltage First Level single phase




Note: CH1,CH2,CH3:grid voltage(1000V/div); CH4,CH5,CH6: current of EUT(20A/div); CH7 trip signal (100mV/div)

Under Voltage First Level all phases



Over voltage First Level all phases



Note: CH1,CH2,CH3:grid voltage(1000V/div); CH4,CH5,CH6: current of EUT(20A/div); CH7 trip signal (100mV/div)

Under Voltage Second Level single phase



Over voltage Second Level single phase



Note: CH1,CH2,CH3:grid voltage(1000V/div); CH4,CH5,CH6: current of EUT(20A/div); CH7 trip signal (100mV/div)

Under Voltage Second Level all phase



Over voltage Second Level all phase



Note: CH1,CH2,CH3:grid voltage(1000V/div); CH4,CH5,CH6: current of EUT(20A/div); CH7 trip signal (100mV/div)


Reconnection after Under Voltage First Level



Reconnection after Over Voltage First Level




Note: CH1,CH2,CH3:grid voltage(1000V/div); CH4,CH5,CH6: current of EUT(20A/div); CH7 trip signal (100mV/div)




Note: CH1,CH2,CH3:grid voltage(1000V/div); CH4,CH5,CH6: current of EUT(20A/div); CH7 trip signal (100mV/div)

5,2,2 Frequency monitoring				P
IEC 61727 8,2 Under and Over Frequency Protection (PEA:2016) 3,10, 12,5 Response to utility recovery (PEA:2016)				
Test conditions:	Any output power level			
	Under frequency		Over frequency	
Parameter		Frequency [Hz]		Frequency [Hz]
Output Voltage		U _N		U _N
Set value		47,00Hz		52,00Hz
Measured trip value(Hz)		47,00		52,01
		47,00		52,01
		47,00		52,01
		Time [ms]		Time [ms]
Limit		<= 100ms		<= 100ms
Disconnection time(ms)	50,0Hz to 47,2 Hz (0,2s min) to 46,5 Hz	58,5	50,0 Hz to 51,80 Hz (0,2s min) to 52,5Hz	62,5
		63,5		57,5
		66,5		66,0
Reconnection time (Sec)	20s – 5min	41,10 s	20s-5min	41,07 s
Note: The frequency which inverter stops feeding power to electrical system in each test must be in the range of the frequency trip setting +/- 0,1Hz and the time it takes to cut off the power must be within 0,1 second, The tests are performed according the IEEE 1547,1-2005, annex A, Response to utility recovery is according to the appropriate IEEE or IEC standard test methods,				

Under Frequency:



Over Frequency:



Note: CH1,CH2,CH3:grid voltage(1000V/div); CH4,CH5,CH6: current of EUT(20A/div); CH7 trip signal (100mV/div)

Reconnection after Under Frequency:



Reconnection after Over Frequency:




Note: CH1,CH2,CH3:grid voltage(1000V/div); CH4,CH5,CH6: current of EUT(20A/div); CH7 trip signal (100mV/div)

**6,1 Islanding protection
3,9, 12,4 Anti-Islanding (PEA:2016)**

Test circuit and parameters

Parameter	Symbol	Units
EUT DC Input		
DC voltage	V_{DC}	V
DC Current	I_{DC}	A
DC Power	P_{DC}	W
EUT AC output		
AC voltage	V_{EUT}	V
AC current	I_{EUT}	A
Real power	P_{EUT}	W
Reactive power	Q_{EUT}	VAR
Test Load		
Resistive load current	I_R	A
Inductive load current	I_L	A
Capacitive load current	I_C	A
AC (utility) power source		
Utility real power	P_{AC}	W
Utility reactive power	Q_{AC}	VAR
Utility current	I_{AC}	A


Block diagram test circuit IEC 62116:2008



IEC 1567/08


Figure 1 – Test circuit for islanding detection function in a power conditioner (inverter)

6,1 Islanding protection according table 6 - Load imbalance (real, reactive load) for test condition A (EUT output = 100%) 3,9, 12,4 Anti-Islanding (PEA:2016)									P
Test conditions		Frequency: 50+/-0,1Hz U _N =220+/-3Vac Distortion factor of chokes < 2% Quality = 1							
Disconnection limit		1s							
No	P _{EUT} ¹⁾ (% of EUT rating)	Reactive load (% of Q _L in 6,1,d) 1)	P _{AC} ²⁾ (% of nominal)	Q _{AC} ³⁾ (% of nominal)	Run on Time (ms)	P _{EUT} (KW per phase)	Actual Q _f	V _{DC} (V)	Remarks ⁴⁾
1	100	100	0	0	117,0	10,040	1,00	812	Test A at BL
2	100	100	-5	-5	111,0	10,040	1,03	812	Test A at BL
3	100	100	-5	0	103,0	10,040	1,05	812	Test A at BL
4	100	100	-5	+5	90,0	10,040	1,05	812	Test A at BL
5	100	100	0	-5	116,0	10,040	0,97	812	Test A at BL
6	100	100	0	+5	80,0	10,040	1,02	812	Test A at BL
7	100	100	+5	-5	115,0	10,040	0,95	812	Test A at BL
8	100	100	+5	0	100,0	10,040	0,95	812	Test A at BL
9	100	100	+5	+5	76,0	10,040	0,97	812	Test A at BL
Parameter at 0% per phase		L= 15,41 mH		R= 4,84 Ω		C= 657,67 μF			
IAC fundamental current(A)		L1: 0,84A		L2: 0,83A		L3: 0,95A			
<p>Note: RLC is adjusted to min, +/-1% of the inverter rated output power 1) P_{EUT}: EUT output power 2) P_{AC}: Real power flow at S1 in Figure 1, Positive means power from EUT to utility, Nominal is the 0 % test condition value, 3) Q_{AC}: Reactive power flow at S1 in Figure 1, Positive means power from EUT to utility, Nominal is the 0 % test condition value, 4) BL: Balance condition, IB: Imbalance condition,</p> <p>Condition A: EUT output power P_{EUT} = Maximum⁵⁾ EUT input voltage⁶⁾ = >90% of rated input voltage range</p> <p>5) Maximum EUT output power condition should be achieved using the maximum allowable input power, Actual output power may exceed nominal rated output, 6) Based on EUT rated input operating range, For example, If range is between X volts and Y volts, 90 % of range = X + 0,9 × (Y – X), Y shall not exceed 0,8 × EUT maximum system voltage (i.e., maximum allowable array open circuit voltage), In any case, the EUT should not be operated outside of its allowable input voltage range,</p>									



6,1 Islanding protection according Table 7 – Load imbalance (reactive load) for test condition B (EUT output = 50 % – 66 %) 3,9, 12,4 Anti-Islanding (PEA:2016)									P
Test conditions		Frequency: 50+/-0,1Hz U _N =220+/-3Vac Distortion factor of chokes < 2% Quality =1							
Disconnection limit		1s							
No	P _{EUT} ¹⁾ (% of EUT rating)	Reactive load (% of Q _L in 6,1,d) 1)	P _{AC} ²⁾ (% of nominal)	Q _{AC} ³⁾ (% of nominal)	Run on Time (ms)	P _{EUT} (KW per phase)	Actual Q _f	V _{DC} (V)	Remarks ⁴⁾
1	66	66	0	-5	96,0	6,660	0,97	540	Test B at IB
2	66	66	0	-4	113,0	6,660	0,97	540	Test B at IB
3	66	66	0	-3	116,0	6,660	0,98	540	Test B at IB
4	66	66	0	-2	126,0	6,660	0,98	540	Test B at IB
5	66	66	0	-1	112,0	6,660	0,98	540	Test B at IB
6	66	66	0	0	128,0	6,660	0,99	540	Test B at BL
7	66	66	0	1	94,0	6,660	0,99	540	Test B at IB
8	66	66	0	2	87,0	6,660	1,00	540	Test B at IB
9	66	66	0	3	90,0	6,660	1,01	540	Test B at IB
10	66	66	0	4	88,0	6,660	1,01	540	Test B at IB
11	66	66	0	5	72,0	6,660	1,02	540	Test B at IB
Parameter at 0% per phase			L=25,51 mH		R= 7,67 Ω		C=434,06 μF		
IAC fundamental current(A)			L1: 0,71A		L2: 0,69A		L3:0,71A		
<p>Note: RLC is adjusted to min, +/-1% of the inverter rated output power 1) P_{EUT}: EUT output power 2) P_{AC}: Real power flow at S1 in Figure 1, Positive means power from EUT to utility, Nominal is the 0 % test condition value, 3) Q_{AC}: Reactive power flow at S1 in Figure 1, Positive means power from EUT to utility, Nominal is the 0 % test condition value, 4) BL: Balance condition, IB: Imbalance condition, Condition B: EUT output power P_{EUT} = 50 % – 66 % of maximum EUT input voltage⁵⁾ = 50 % of rated input voltage range, ±10 % 5) Based on EUT rated input operating range, For example, If range is between X volts and Y volts, 50 % of range =X + 0,5 × (Y – X), Y shall not exceed 0,8 × EUT maximum system voltage (i.e., maximum allowable array open circuit voltage), In any case, the EUT should not be operated outside of its allowable input voltage range,</p>									

Disconnection at P_{AC} 0% and Q_{AC} 0% reactive load No, 6



Attention:


For Thailand only picture with all three current phases L1, L2 and L3 are accepted

All relays are direct coupled and open directly by receiving the islanding signal from the controller,

Note:

CH6, CH7, CH8: L1, L2, L3 current of EUT(20A/div), CH5: Trigger signal(10A/div)

6,1 Islanding protection according Table 7 – Load imbalance (reactive load) for test condition C (EUT output = 25 % – 33 %) 3,9, 12,4 Anti-Islanding (PEA:2016)									P
Test conditions		Frequency: 50+/-0,1Hz U _N =220+/-3Vac Distortion factor of chokes < 2% Quality =1							
Disconnection limit		1s							
No	P _{EUT} ¹⁾ (% of EUT rating)	Reactive load (% of Q _L in 6,1,d) 1)	P _{AC} ²⁾ (% of nominal)	Q _{AC} ³⁾ (% of nominal)	Run on Time (ms)	P _{EUT} (kW per phase)	Actual Q _f	V _{DC} (V)	Remarks ⁴⁾
1	33	33	0	-5	106,0	3,330	0,95	268	Test C at IB
2	33	33	0	-4	123,0	3,330	0,95	268	Test C at IB
3	33	33	0	-3	114,0	3,330	0,95	268	Test C at IB
4	33	33	0	-2	113,0	3,330	0,96	268	Test C at IB
5	33	33	0	-1	112,0	3,330	0,96	268	Test C at IB
6	33	33	0	0	149,0	3,330	0,97	268	Test C at BL
7	33	33	0	1	99,0	3,330	0,97	268	Test C at IB
8	33	33	0	2	102,0	3,330	0,98	268	Test C at IB
9	33	33	0	3	90,0	3,330	0,98	268	Test C at IB
10	33	33	0	4	81,0	3,330	0,99	268	Test C at IB
11	33	33	0	5	69,0	3,330	0,99	268	Test C at IB
Parameter at 0% per phase		L= 50,57 mH		R= 15,89 Ω		C= 200,37 μF			
IAC fundamental current(A)		L1: 0,52A		L2: 0,56A		L3: 0,59A			
<p>Note: RLC is adjusted to min, +/-1% of the inverter rated output power 1) P_{EUT}: EUT output power 2) P_{AC}: Real power flow at S1 in Figure 1, Positive means power from EUT to utility, Nominal is the 0 % test condition value, 3) Q_{AC}: Reactive power flow at S1 in Figure 1, Positive means power from EUT to utility, Nominal is the 0 % test condition value, 4) BL: Balance condition, IB: Imbalance condition, Condition C: EUT output power P_{EUT} = 25 % – 33 %⁵⁾ of maximum EUT input voltage⁶⁾ = <10 % of rated input voltage range 5) Or minimum allowable EUT output level if greater than 33 %, 6) Based on EUT rated input operating range, For example, If range is between X volts and Y volts, 10 % of range =X + 0,1 × (Y – X), Y shall not exceed 0,8 × EUT maximum system voltage (i.e., maximum allowable array open circuit voltage), In any case, the EUT should not be operated outside of its allowable input voltage range,</p>									



Attention:

For Thailand only picture with all three current phases L1, L2 and L3 are accepted

All relays are direct coupled and open directly by receiving the islanding signal from the controller,

Note:


CH6, CH7, CH8: L1, L2, L3 current of EUT(20A/div), CH5: Trigger signal(10A/div)

PEA:2016 additional test						P
3,4 Reactive power control(PEA:2016)						P
Test conditions:		Input: 600 Vdc Output: 220 Vac				
P (setting)	P(kW)ind	P(kW)cap	Q(kVar)ind, max	Q(kVar)cap, max	PFind, max	PFcap, max
0%	1,42	1,44	-0,585	0,284	0,955	0,964
10%	2,956	2,963	-1,016	0,945	0,96	0,941
20%	5,987	5,993	-2,067	1,879	0,953	0,949
30%	9,005	9,012	-3,029	2,966	0,953	0,946
40%	12,006	12,017	-4,015	4,000	0,952	0,946
50%	15,003	15,011	-4,993	5,034	0,952	0,945
60%	17,988	18,001	-5,966	6,076	0,952	0,945
70%	20,97	20,982	-6,946	7,109	0,951	0,945
80%	23,995	23,888	-7,959	8,095	0,951	0,945
90%	26,979	26,882	-8,965	9,136	0,951	0,945
100%	29,942	29,848	-9,964	10,099	0,95	0,946
Note:						

PEA:2016 additional test					P
3,4,1, 8,1,2 1) A fixed displacement factor $\cos\phi$					P
Test conditions:		Input: 600Vdc Output: 220Vac			
P (setting)	PF (setting)	P(kW)	Q(kVar)	PF	
0%	0,95 lagging	1,420	-0,585	0,955	
10%	0,95 lagging	2,956	-1,016	0,960	
20%	0,95 lagging	5,987	-2,067	0,953	
30%	0,95 lagging	9,005	-3,029	0,953	
40%	0,95 lagging	12,006	-4,015	0,952	
50%	0,95 lagging	15,003	-4,993	0,952	
60%	0,95 lagging	17,988	-5,966	0,952	
70%	0,95 lagging	20,970	-6,946	0,951	
80%	0,95 lagging	23,995	-7,959	0,951	
90%	0,95 lagging	26,979	-8,965	0,951	
100%	0,95 lagging	29,942	-9,964	0,950	
P (setting)	PF (setting)	P(kW)	Q(kVar)	PF	
0%	0,95 leading	1,440	0,284	0,964	
10%	0,95 leading	2,963	0,945	0,941	
20%	0,95 leading	5,993	1,879	0,949	
30%	0,95 leading	9,012	2,966	0,946	
40%	0,95 leading	12,017	4,000	0,946	
50%	0,95 leading	15,011	5,034	0,945	
60%	0,95 leading	18,001	6,076	0,945	
70%	0,95 leading	20,982	7,109	0,945	
80%	0,95 leading	23,888	8,095	0,945	
90%	0,95 leading	26,882	9,136	0,945	
100%	0,95 leading	29,848	10,099	0,946	
P (setting)	PF (setting)	P(kW)	Q(kVar)	PF	
0%	1,00	1,431	-0,224	0,998	
10%	1,00	2,972	-0,285	0,999	
20%	1,00	6,007	-0,413	0,999	
30%	1,00	9,047	-0,528	0,999	




40%	1,00	12,065	-0,663	0,999
50%	1,00	15,024	-0,782	0,999
60%	1,00	18,055	-0,931	0,999
70%	1,00	21,062	-1,061	0,999
80%	1,00	23,990	-1,212	0,999
90%	1,00	27,024	-1,362	0,999
100%	1,00	30,006	-1,515	0,999
Note:				

<p>PEA:2016 additional test</p>	<p>N/A</p>
<p>3,4,2, 8,1,2 2) A variable reactive power depending on the voltage Q(U) (PEA:2016) (Power generation system is greater than 500kW)</p>	<p>N/A</p>
<p>The purpose of the test is to ensure that the converter complies with the methods for automatically supplying reactive power according to the standard characteristic curve Q(U) indicated in 1,5, Activation must be at the Distributor's request, when the Operating Regulations are issued, The Distributor shall also specify the values of the parameters that uniquely characterise the curve, i.e.: V1i, V2i, V1s and V1s as well as the lock-in value of active power (default value $P = 0,2 P_n$), The parameters V1i, V2i, V1s and V1s should be set in the range between 0,9 and 1,1 with 0,01 V_n steps, In order to facilitate execution of the type tests, the characterising parameters are conventionally set as follows: V1s = 1,08 V_n; V2s = 1,1 V_n V1i = 0,92 V_n; V2i = 0,9 V_n and the active power lock-in value (default value $P = 0,2 P_n$),</p>  <p>The graph shows a characteristic curve of reactive power Q versus voltage V. The vertical axis is labeled Q and has marks for Qmax and -Qmax. The horizontal axis is labeled V and has marks for V2i, V2s, V1s, and V1i. The curve is a red line that is constant at Qmax for V < V2i, then decreases linearly from (V2i, Qmax) to (V2s, 0). It remains at 0 for V between V2s and V1s, then decreases linearly from (V1s, 0) to (V1i, -Qmax), and remains constant at -Qmax for V > V1i. Text to the right of the graph specifies: V2s = 1,1 Vn, V1s = 1,08 Vn, V2i = 0,92 Vn, and V1i = 0,9 Vn.</p>	

Qmin reactive power in accordance to standard characteristic curve Q=f(V)						
P/Pn	Vac [V] Set point	P[kW] measured	Vac [V] measured	Q [kVar] measured	Q [kVar] expected	ΔQ [kVar]
< 20%	1,07Vn	--	--	--	--	--
< 20%	1,09Vn	--	--	--	--	--
< 20%-30%	1,09Vn	--	--	--	--	--
40%	1,09Vn	--	--	--	--	--
50%	1,09Vn	--	--	--	--	--
60%	1,09Vn	--	--	--	--	--
70%	1,09Vn	--	--	--	--	--
80%	1,09Vn	--	--	--	--	--
90%	1,09Vn	--	--	--	--	--
100%	1,09Vn	--	--	--	--	--
100%	1,1 Vn	--	--	--	--	--
100%-10%	1,1 Vn	--	--	--	--	--
10%→ ≤5%	1,1 Vn	--	--	--	--	--
Qmax reactive power in accordance to standard characteristic curve Q=f(V)						
P/Pn	Vac [V] Set point	P[kW] measured	Vac [V] measured	Q [kVar] measured	Q [kVar] expected	ΔQ [kVar]
< 20%	0,93Vn	--	--	--	--	--
< 20%	0,91Vn	--	--	--	--	--
< 20%-30%	0,91Vn	--	--	--	--	--
40%	0,91Vn	--	--	--	--	--
50%	0,91Vn	--	--	--	--	--
60%	0,91Vn	--	--	--	--	--
70%	0,91Vn	--	--	--	--	--
80%	0,91Vn	--	--	--	--	--
90%	0,91Vn	--	--	--	--	--
100%	0,91Vn	--	--	--	--	--
100%	0,91Vn	--	--	--	--	--
100%-10%	0,90Vn	--	--	--	--	--
10%→ ≤5%	0,90Vn	--	--	--	--	--
Note: The lock-in value is adjustable between Vn and 1,1Vn and the lock-out value between Vn and 0,9Vn in 0,01V steps, Power generation system is less than 500kW						

PEA:2016 additional test			P
3,5, 12,1 Active power control (PEA:2016)			P
Setpoint in power bin [%]	P _{setpoint} [kW]	P ₆₀ [kW]	Decrease time (s)
100%	30,0	29,997	
90%	27,0	26,973	2s
80%	24,0	23,948	2s
70%	21,0	20,943	2s
60%	18,0	17,950	2s
50%	15,0	14,971	5s
40%	12,0	11,963	2s
30%	9,0	8,967	0,2s
20%	6,0	5,975	2s
10%	3,0	2,997	2s
0%	0,0	1,736	2s

Graph of the setting accuracy



Note:



PEA:2016 additional test		N/A
3,6, 12,2 Low voltage fault Ride through capability (PEA:2016) (Power generation system is greater than 500kW)		N/A
Test List	V(V/V_n)	Duration time (Sec)
Test P>0,9P _n *		
Three-phase faults	--	--
	--	--
	--	--
Phase to phase faults		
	--	--
	--	--
	--	--
Single phase to ground faults		
	--	--
	--	--
	--	--
Test P=0,3P _n		
Three-phase faults	--	--
	--	--
	--	--
Phase to phase faults		
	--	--
	--	--
	--	--
Single phase to ground faults		
	--	--
	--	--
	--	--
Test P=0,1 P _n		
Three-phase faults	--	--
	--	--
	--	--
Phase to phase faults		
	--	--
	--	--
	--	--


Single phase to ground faults	--	--
	--	--
	--	--

Note:

The PGS must not disconnected from grid while the PCC voltage dip period less than below curve limit,

- install and connect the PGS and recommendation of the technical requirements of the equipment manufacturer ,
- Check all parameters of power supply in normal conditions, the operation of power system equipment ,
- testing by simulation the voltage , (I try to short-circuit in the power network) in the electricity network to balance the pressure between $70-80\%V_n$, $30-50\%V_n$, and less than 5 percent of the normal operating pressure ,
- Record the maximum time power system can still connect to the electricity network as shown on above table,

Power generation system is less than 500kW



Annex 1

Pictures of the unit

Enclosure front view



Enclosure top view



Enclosure side view



Enclosure side view




Enclosure bottom view




Enclosure side view




Inside view




PCB view – 1 of main power board




PCB view – 2 of main power board




PCB view – 1 of control board




PCB view – 2 of control board




PCB view – 1 of Communication board




PCB view – 2 of Communication board




PCB view – 1 of power Output board




PCB view – 2 of power Output board




PCB view – 1 of power Input board




PCB view – 2 of power Input board




PCB view – 1 of Display board




PCB view – 2 of Display board




PCB view – 1 of AC lightning protection board




PCB view – 2 of AC lightning protection board



PCB view – 1 of PV String board



PCB view – 2 of PV String board



Annex 2

Test equipment list

Dates of performance test: 2021-05-04 to 2021-08-24

Equipment	Internal No.	Manufacturer	Type	Serial No.	Last Calibration
Power Analyzer	A4080002DG	YOKOGAWA	WT3000	91M210852	Jul. 19, 2021
Power Analyzer	A4080004DG	DEWESoft	--	DB19104221	Jul. 18, 2021
AC Source	A7040019DG	Chroma	61512	61512000439	Monitored by Power Analyzer
AC Source	A7040020DG	Chroma	61512	61512000438	
DC Simulation Power Supply	A7040016DG	Chroma	62150H-1000S	62150EF00490	
DC Simulation Power Supply	A7040017DG	Chroma	620028	620028EF00120	
RLC Load	A7150027DG	Qunling	ACLT-3803H	93VOO2869	
Eight Channel Digital Phosphor Oscilloscope	A4089017DG	YOKOGAWA	DL850	91N726247	Sep. 24, 2020
Oscilloscope probel	A1490008DG	YOKOGAWA	701901	//	Aug. 12, 2021
Oscilloscope probel	A1490009DG	YOKOGAWA	701901	//	Aug. 12, 2021
Oscilloscope probel	A1490010DG	YOKOGAWA	701901	//	Aug. 12, 2021
Current transducer	A1060007DG	YOKOGAWA	CT200	1130700012	Aug. 09, 2021
Current transducer	A1060008DG	YOKOGAWA	CT200	1130700017	Aug. 09, 2021
Current transducer	A1060009DG	YOKOGAWA	CT200	1130700019	Aug. 09, 2021